CERTIFICATE

Issued to:
Applicant:
Schneider Electric Industries SAS
31 Rue Pierre Mendes France
38320 Eybens, France

Product	:	surge protective devices
Trade name(s)	:	SCHNEIDER ELECTRIC
Type(s)/model(s)	:	16314 - C1 Master-350, 16317 - C1 Neutral-350, 16360 - PRD 1 Master 1P, 16361 - PRD 1 Master 1P+N, 16362 - PRD 1 Master 3P and 16363 - PRD 1 Master 3P+N

The product and any acceptable variation thereof as specified in the Annex to this certificate and the documents referred to therein.

DEKRA hereby declares that the above-mentioned product has been certified based on:
- a type test according to EN 61643-11:2012 and EN 61643-11:2012/A11:2018
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 900469
- the licensee is registered with the number 676000

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 20 January 2026 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-167135

DEKRA Certification B.V.

B.T.M. Holtus
Managing Director

Miranda Zhou
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL

PRODUCTS RvA C 001

KEMA KEUR

DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, Netherlands
T +31 88 96 83000 F +31 88 96 83100 www.dekra.nl Company registration 09085396

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	surge protective devices
Trade name(s)	:	SCHNEIDER ELECTRIC
Type(s)/model(s)	:	16314 - C1 Master-350, 16317 - C1 Neutral-350, 16360 - PRD 1 Master 1P, 16361 - PRD 1 Master 1P+N, 16362 - PRD 1 Master 3P and 16363 - PRD 1 Master 3P+N
SPD type/class	:	1/I
Voltage protection level (Up)	:	1,5 kV
Short-circuit current rating (Isccr)	:	50 kA
Overcurrent protection	:	315 A gG
Rated load current (IL)	:	125 A

Product data – type 16314 - C1 Master-350

Plug	:	one pole
Maximum continuous operating voltage (Uc)	:	350 Vac
Impuls discharge current (Iimp)	:	25 kA

Product data – type 16317 - C1 Neutral-350

Plug	:	one pole
Maximum continuous operating voltage (Uc)	:	350 Vac
Impuls discharge current (Iimp)	:	100 kA

Product data – type 16360 - PRD 1 Master 1P

Socket with plugs	:	one pole with remote contact
Plugs	:	1 x C1 Master-350
Maximum continuous operating voltage (Uc)	:	350 Vac
Impuls discharge current (Iimp)	:	25 kA

Product data – type 16361 - PRD 1 Master 1P+N

Socket with plugs	:	two pole with remote contact
Plugs	:	1 x C1 Master-350 + 1 x C1 Neutral-350
Maximum continuous operating voltage (Uc)	:	350 Vac
Impuls discharge current (Iimp)	:	L/N - 25 kA N/PE - 100 kA
Total discharge current (ITotal)	:	50 kA

Product data – type 16362 - PRD 1 Master 3P

Socket with plugs	:	three pole with remote contact
Plugs	:	3 x C1 Master-350
Maximum continuous operating voltage (Uc)	:	350 Vac
Impuls discharge current (Iimp)	:	25 kA
Total discharge current (ITotal)	:	75 kA

Product data – type 16363 - PRD 1 Master 3P+N

Socket with plugs	:	four pole with remote contact

Plugs	:	3 x C1 Master-350 + 1 x C1 Neutral-350
Maximum continuous operating voltage (Uc)	:	350 Vac
Impuls discharge current (Iimp)	:	L/N - 25 kA N/PE - 100 kA
Total discharge current (ITotal)	:	100 kA

TESTS

Test requirements
EN 61643-11:2012
EN 61643-11:2012/A11:2018

Test result
The test results are documented in DEKRA test file 230314100.

Additional information
This certificate replaces certificate No. 2170677.02 which we hereby declare invalid.

Conclusion
The examination has confirmed that all requirements were met.

Factory locations
The factory locations are registered with the numbers 676000, 326192 and 87926.