



DBFPMK Power Meter Kit Installation Instructions

OPERATION

The PDL Cat DBFPMK Power Meter Kit provides a simple solution for mounting power meters and ripple relays into the PDL Superboard range of products.

INSTALLATION

The kit is for use with 60 Way Flush, and 60 Way Surface Boards.

- 1) Mount the bottom support barrier to the base of the Superboard using the two fixing screws provided. No 8 x 3/8.
- 2) Mount the power meters and ripple relays to the bottom support barrier as required.
- 3) Cut the front cover of the Superboard to suit the power meters and ripple relays.
- 4) Fix the clear plastic lens to the front cover of the Superboard using the four plastic rivets provided. (Drill 4mm $\pm$.1mm dia holes).

IMPORTANT NOTES

- 1) Do not use metal fasteners to fix the clear plastic lens.
- 2) Ensure the clear plastic lens is fitted securely with no access to the internal area of the board.
- 3) This kit has been designed around and best suited for the Enermet Ripple control receiver - Type R03, and the Enermet E130 / ERBi Power Meter and Remote Register. Other standard meters may not fit.

PRODUCT WARRANTY/12 MONTHS

This product has a 12 month warranty from the date of purchase providing the unit is installed according to these instructions, local wiring regulations and Codes of Practice. This warranty is void on any unit which has been tampered with, damaged by accident improper operation or incorrect installation, This guarantee is in addition to, and does not in any way affect the rights under the Consumer Guarantees Act 1993, if the ACT applies to the supply of this product and you are not acquiring the product for a business use. If the ACT applies and any term is inconsistent with the terms or requirements of the ACT that term shall be invalid without affecting the remaining terms of the warranty. Note: Under the CGA 1993, Schneider Electric advises that this product does not contain user serviceable components thus spare parts and repair facilities are not available. In the event of a warranty claim, the product must be returned to the point of purchase or direct to Australia/New Zealand distributors together with the proof of purchase.



P D L

New Zealand Head Office:
PO Box 15 355, New Lynn, Auckland, New Zealand
Telephone +64-9-829 0490, Fax +64-9-829 0491
www.pdl.co.nz



Electrical Products

PDL Industries Australia Pty Ltd
Locked Bag 5500, Baulkham Hills Business Centre
Baulkham Hills NSW 2153 Australia
Freephone 1300 735 266, Freefax 1300 735 329
Telephone +61 29851 2666, Fax: +61 29851 2695
www.pdl.com.au



827892

Rev1 CN13000



DBFPMK Power Meter Kit Installation Instructions

OPERATION

The PDL Cat DBFPMK Power Meter Kit provides a simple solution for mounting power meters and ripple relays into the PDL Superboard range of products.

INSTALLATION

The kit is for use with 60 Way Flush, and 60 Way Surface Boards.

- 1) Mount the bottom support barrier to the base of the Superboard using the two fixing screws provided. No 8 x 3/8.
- 2) Mount the power meters and ripple relays to the bottom support barrier as required.
- 3) Cut the front cover of the Superboard to suit the power meters and ripple relays.
- 4) Fix the clear plastic lens to the front cover of the Superboard using the four plastic rivets provided. (Drill 4mm $\pm$.1mm dia holes).

IMPORTANT NOTES

- 1) Do not use metal fasteners to fix the clear plastic lens.
- 2) Ensure the clear plastic lens is fitted securely with no access to the internal area of the board.
- 3) This kit has been designed around and best suited for the Enermet Ripple control receiver - Type R03, and the Enermet E130 / ERBi Power Meter and Remote Register. Other standard meters may not fit.

PRODUCT WARRANTY/12 MONTHS

This product has a 12 month warranty from the date of purchase providing the unit is installed according to these instructions, local wiring regulations and Codes of Practice. This warranty is void on any unit which has been tampered with, damaged by accident improper operation or incorrect installation, This guarantee is in addition to, and does not in any way affect the rights under the Consumer Guarantees Act 1993, if the ACT applies to the supply of this product and you are not acquiring the product for a business use. If the ACT applies and any term is inconsistent with the terms or requirements of the ACT that term shall be invalid without affecting the remaining terms of the warranty. Note: Under the CGA 1993, Schneider Electric advises that this product does not contain user serviceable components thus spare parts and repair facilities are not available. In the event of a warranty claim, the product must be returned to the point of purchase or direct to Australia/New Zealand distributors together with the proof of purchase.



P D L

New Zealand Head Office:
PO Box 15 355, New Lynn, Auckland, New Zealand
Telephone +64-9-829 0490, Fax +64-9-829 0491
www.pdl.co.nz



Electrical Products

PDL Industries Australia Pty Ltd
Locked Bag 5500, Baulkham Hills Business Centre
Baulkham Hills NSW 2153 Australia
Freephone 1300 735 266, Freefax 1300 735 329
Telephone +61 29851 2666, Fax: +61 29851 2695
www.pdl.com.au



827892

Rev1 CN13000