SpaceLogic C-Bus SOLIS™ C Touch Panel Version 1.3.0 Release Notes

SpaceLogic C-Bus

Table of Contents

SpaceLogic C-Bus SOLIS™ C Touch Panel 1.3.0 3

Release 1.3.0 3

What's New 3

Fixes 3

Known Issues 3

Touch Panel 1.2.0 4

What's New 4

Fixes 4

Known Limitations 4

Touch Panel 1.1.0 5

Released 5

What's New 5

Fixes 5

Known Limitations 5

SpaceLogic C-Bus SOLIS™ C Touch Panel 1.3.0

Release 1.3.0

Oct 2026

What's New

Improved user experience when using Screen Sleep operation.

Fixes

Resolved the issue where the Touch Panel could experience delayed responsiveness after waking from Screen Sleep mode. Reconnection to the Automation Controller is now more reliable.

Known Issues

None.

Touch Panel 1.2.0

Oct 2026

What's New

- Enhancement of event-driven navigation & notifications feature.
- Beta program enrolment feature, allowing eligible customers to access and evaluate pre-release software updates.
- Improvement of feature descriptions & terminologies in the touch panel such Remote panel update.

Fixes

None.

Known Limitations


NOTICE

C-BUS SOLIS™ C TOUCH PANEL SCREEN SLEEP OPERATION

When a C-Bus SOLIS™ C Touch Panel is configured with Screen Sleep, the panel may require additional time to reconnect to the controller after being in sleep for an extended period of inactivity. During this reconnection process, control commands may not respond immediately, and normal operation can take some time to resume after the panel is woken up from sleep.

Recommended Configuration

For optimal performance when using Screen Sleep on the Touch Panel, enable the **Remember username and password** option in the Automation Controller **User access settings** as shown below.



With this option enabled, the Touch Panel maintains authentication information and can reconnect seamlessly, when waking from Sleep Mode.

Failure to follow these instruction s may result in delayed operation of the Touch Panel after waking from sleep.

Touch Panel 1.1.0

Released

October 2026

What's New

- Event-driven navigation and notifications for a more intuitive user experience.
- Instant response capability for a faster and more responsive user experience.
- Support for both 24 V DC and PoE+ power options.
- Android 13 platform with enhanced cybersecurity features.
- Higher resolution 1920 × 1200 display for improved visual clarity.
- Wired and Wireless connectivity
- Integration with Automation Controller's PC Visualization and Manager UI
- No re-login required following session expiry.

Fixes

None

Known Limitations


NOTICE

C-BUS SOLIS™ C TOUCH PANEL SCREEN SLEEP OPERATION

When a C-Bus SOLIS™ C Touch Panel is configured with Screen Sleep, the panel may require additional time to reconnect to the controller after being in sleep for an extended period of inactivity. During this reconnection process, control commands may not respond immediately, and normal operation can take some time to resume after the panel is woken up from sleep.

Recommended Configuration

For optimal performance when using Screen Sleep on the Touch Panel, enable the **Remember username and password** option in the Automation Controller **User access settings** as shown below.



With this option enabled, the Touch Panel maintains authentication information and can reconnect seamlessly, when waking from Sleep Mode.

Failure to follow these instruction s may result in delayed operation of the Touch Panel after waking from sleep.