

## Kitchens

Kitchens shall use switched compact fluorescent area lighting and switched LED bench top lighting. A local control panel shall operate the lighting.

| Button | Function           | Button | Function                |
|--------|--------------------|--------|-------------------------|
| 1      | Area lights on/off | 2      | Bench top lights on/off |

Table 15 – Functions, kitchen local control panel

| Device Ref. | Cat. No.  | Description                            | Channel ID |
|-------------|-----------|----------------------------------------|------------|
| RLY         | L5508RVFP | 8 Channel C-Bus DIN Voltage Free Relay |            |
| LCP         | 5082NL,GF | 2 Button C-Bus Saturn Wall Switch      |            |

Table 16 – Kitchen lighting control system units

## Lift Lobby Areas

Lift lobby areas shall use switched compact fluorescent lighting with a switched LED downlight which operates 24 hours. Compact fluorescent (CF) lighting shall remain on during business hours. It shall be operated by schedule and controlled by the Schedule Controller. During after hours operation, CF lift lobby lighting shall be activated by a ceiling mounted 360° PIR occupancy sensor with a 5 minute timer.

| Device Ref. | Cat. No.  | Description                            | Channel ID |
|-------------|-----------|----------------------------------------|------------|
| RLY         | L5508RVFP | 8 Channel C-Bus DIN Voltage Free Relay |            |
| OCS         | 5753L     | C-Bus 360° PIR Occupancy Sensor        |            |

Table 17 – Lift lobby area control system units

## Loading Dock

The loading dock lighting shall be activated via a schedule during standard working hours. The schedule shall be controlled by the Schedule Controller. After hours activation shall be operated via a local control panel.

Whenever dock lighting is active, lighting shall be switched via a light level sensor. The threshold of the light level sensor shall be set so as to prevent cycling of the lights due to fluctuations in ambient lighting level. The light level sensor shall be positioned so it will be unaffected by artificial light. The loading dock lighting shall switch off when Master Off is set.

| Button | Function      |
|--------|---------------|
| 1      | Lights on/off |

Table 18 – Function, loading dock local control panel

| Device Ref. | Cat. No.  | Description                            | Channel ID |
|-------------|-----------|----------------------------------------|------------|
| RLY         | L5504RVFP | 4 Channel C-Bus DIN Voltage Free Relay |            |
| LLS         | 5031PE    | C-Bus Light Level Sensor               |            |
| LCP         | SC5031NL  | 1 Button C-Bus Slimline Wall Switch    |            |

Table 19 – Loading dock lighting control system units