

Certificate of Conformity

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the authorised Approval Mark on the product of the same type and the Regulatory Compliance Mark (RCM) mark provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the Approval and RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. – This Certificate meets the requirements of a Recognised External Certification Scheme (EESS- RECS) and a Recognised External Approval Scheme (NSW-REAS).

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	Schneider Electric (Australia) Pty Ltd	Other Name	
Address	33-37 Port Wakefield Road Gepps Cross SA 5094 Australia		
Client ID	102093	Global-Mark File Number:	102093-367
Certificate Number & Approval Mark	GMA-519097-EA	Revision Number	00
Certification Standard(s)	AS/NZS 61009.1:2015 including A1 Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) - General rules		
Type of Certification	Electrical Safety Product	Scheme	Global-Mark Electrical Product Safety Certification Scheme

System 1 Approval

CERTIFICATE DATES

Certificate Issue Date	10/09/2024
Certificate Last Update Date	
Certification Expiry Date	10/09/2029

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager



Certificate of Conformity

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Residual Current Device	A9 iC60N3 RCBO	Schneider Electric	A9DC5910	400/415Vac, 50Hz, 10A, 10mA, 3+N, Type A, C Curve, 6000A
Residual Current Device	A9 iC60N3 RCBO	Schneider Electric	A9DC5916	400/415Vac, 50Hz, 16A, 10mA, 3+N, Type A, C Curve, 6000A
Residual Current Device	A9 iC60N3 RCBO	Schneider Electric	A9DC5920	400/415Vac, 50Hz, 20A, 10mA, 3+N, Type A, C Curve, 6000A
Residual Current Device	A9 iC60N3 RCBO	Schneider Electric	A9DC6906	400/415Vac, 50Hz, 6A, 30mA, 3+N, Type A, C Curve, 6000A
Residual Current Device	A9 iC60N3 RCBO	Schneider Electric	A9DC6910	400/415Vac, 50Hz, 10A, 30mA, 3+N, Type A, C Curve, 6000A
Residual Current Device	A9 iC60N3 RCBO	Schneider Electric	A9DC6916	400/415Vac, 50Hz, 16A, 30mA, 3+N, Type A, C Curve, 6000A
Residual Current Device	A9 iC60N3 RCBO	Schneider Electric	A9DC6920	400/415Vac, 50Hz, 20A, 30mA, 3+N, Type A, C Curve, 6000A
Residual Current Device	A9 iC60N3 RCBO	Schneider Electric	A9DC6925	400/415Vac, 50Hz, 25A, 30mA, 3+N, Type A, C Curve, 6000A
Residual Current Device	A9 iC60N3 RCBO	Schneider Electric	A9DC6932	400/415Vac, 50Hz, 32A, 30mA, 3+N, Type A, C Curve, 6000A
Residual Current Device	A9 iC60N3 RCBO	Schneider Electric	A9DC6940	400/415Vac, 50Hz, 40A, 30mA, 3+N, Type A, C Curve, 6000A
Residual Current Device	A9 iC60N3 RCBO	Schneider Electric	A9DC6950	400/415Vac, 50Hz, 50A, 30mA, 3+N, Type A, C Curve, 6000A
Residual Current Device	A9 iC60N3 RCBO	Schneider Electric	A9DC6963	400/415Vac, 50Hz, 63A, 30mA, 3+N, Type A, C Curve, 6000A

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION
suitable for sale in New Zealand

End of document

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager


