

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

Schneider Shanghai Low Voltage Terminal Apparatus Co.,Ltd.
No.1319 Ping'an Road, Minhang District,Shanghai, P.R.China

Name and address of the manufacturer

Schneider Shanghai Low Voltage Terminal Apparatus Co.,Ltd.
No.1319 Ping'an Road, Minhang District,Shanghai, P.R.China

Name and address of the factory

Schneider Shanghai Low Voltage Terminal Apparatus Co.,Ltd.
No.1319 Ping'an Road, Minhang District, Shanghai, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

Clipsal

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

4SW, 4MSW, RMSW, SW, MAX9;

Additional information (if necessary may also be reported on page 2)

IEC 60947-1:2020;IEC 60947-3:2020

A sample of the product was tested and found to be in conformity with

CB2021CQC-096573

As shown in the Test Report Ref. No. which forms part of this Certificate

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Jun.29,2021

Signature:



Xie ZhaoXu

4SW, 4MSW, RMSW, SW, MAX9

Uimp:6kV;

Ui: 4SW, 4MSW, RMSW, SW: 250V(1P),500V(2P,3P); MAX9: 500V(1P,2P,3P);

Ith: 4SW, 4MSW, RMSW, SW: 80A(1P),100A(1P,2P,3P),125A(1P,2P,3P); MAX9: 100A(1P,2P,3P);

Ue:240V(1P),415V(2P,3P);

Ie: 4SW, 4MSW, RMSW, SW: 80A(1P),100A(1P,2P,3P),125A(1P,2P,3P); MAX9: 100A(1P,2P,3P);

Icw:1500A 1s;

Icm:5kA;

Iq:4SW, 4MSW, RMSW, SW: 10kA; MAX9: 6kA;

Utilization category:AC-22A;

Poles:1P,2P,3P;

50/60Hz;

IP20;

Page 1 of 1

Additional information (if necessary)

Date: Jun.29,2021

Signature:

谢肇煦

Xie ZhaoXu