



Ref. Certif. No.

SE-115043

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit-breakers for overcurrent protection for household and similar installations (CBOs)

Name and address of the applicant

Schneider Electric Industries SAS
35 rue Joseph Monier
92500 Rueil-Malmaison
FRANCE

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Schneider Shanghai Low Voltage Terminal Apparatus Co., Ltd.
1319 Pingan Rd., Minghang zone, Shanghai, P.R.China

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

Ue= 240V~(1P+N), 50/60Hz
In= 6, 10, 16, 20, 25, 32, 40A
Ics= Icn= 6000A, C- type, Energy limiting class 3

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

MAX9

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60898-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

2406B1920SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 16 October, 2024

Signature:

Quan Li