Ref. Certif. No.

CN73057

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	AC Contactor
Name and address of the applicant	Schneider Electric Manufacturing (Wuhan) Co., Ltd. No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone, Wuhan, Hubei Province, P.R.China
Name and address of the manufacturer	Schneider Electric Manufacturing (Wuhan) Co., Ltd. No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone, Wuhan, Hubei Province, P.R.China
Name and address of the factory Note: *When more than one factory, please report on page 2*	Schneider Electric Manufacturing (Wuhan) Co., Ltd. No.1 3rd Fozuling Road, Donghu New&High Tech Development Zone, Wuhan, Hubei Province, P.R.China
Ratings and principal characteristics	See the Appendix
Trademark (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	LC1DS09, LC1DS12, LC1DS18;
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2020;IEC 60947-4-1:2023
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2025CQC-123202

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Sep.03,2025

Signature: 谢肇煦
Xie ZhaoXu

LC1DS09, LC1DS12, LC1DS18
Ui: 690V;
Uimp: 6kV;
LC1DS09:
Ith: 25A;
AC-1: Ue/Ie: 220V/230V/25A, 380V/400V/25A, 660V/690V/25A;
AC-3: Ue/Ie: 220V/230V/9A, 380V/400V/9A, 660V/690V/6.6A;
AC-4: Ue/Ie: 220V/230V/7.5A, 380V/400V/7.5A, 660V/690V/5.5A;
AC-3e: Ue/Ie: 220V/230V/9A, 380V/400V/9A, 660V/690V/6.6A;
LC1DS12:
Ith: 25A;
AC-1: Ue/Ie: 220V/230V/25A, 380V/400V/25A, 660V/690V/25A;
AC-3: Ue/Ie: 220V/230V/12A, 380V/400V/12A, 660V/690V/6.9A;
AC-4: Ue/Ie: 220V/230V/10A, 380V/400V/10A, 660V/690V/5.8A;
AC-3e: Ue/Ie: 220V/230V/12A, 380V/400V/12A, 660V/690V/6.9A;
LC1DS18:
Ith: 32A;
AC-1: Ue/Ie: 220V/230V/32A, 380V/400V/32A, 660V/690V/32A;
AC-3: Ue/Ie: 220V/230V/18A, 380V/400V/18A, 660V/690V/11.5A;
AC-4: Ue/Ie: 220V/230V/15A, 380V/400V/15A, 660V/690V/9.6A;
AC-3e: Ue/Ie: 220V/230V/18A, 380V/400V/18A, 660V/690V/11.5A;
Us: AC24V, 36V, 48V, 110V, 220V,380V 50/60Hz;
Pole: 3P;
Frequency: 50/60Hz;
IP20(only front face);
Auxiliary contacts: (body)
Ith:10A;
AC-15: Ue/Ie: 120V/6A, 600V/1.2A;
DC-13: Ue/Ie: 125V/1.1A, 600V/0.2A;
1NO1NC

Additional information (if necessary)

Date: Sep.03,2025

Signature: 谢肇煦
Xie ZhaoXu

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
http://www.cqc.com.cn