

6 October 2022

Univolt Extrusions (Dongguan) Limited
Dongshan Yongfa Industrial Area, Qi Shi Town
Dongguan, Guangdong, 523511
CHINA

Attention: Elisa Chen, AS-CERT technical Service (Shanghai) Co., Ltd.

CERTIFICATION OF ELECTRICAL EQUIPMENT

It is our pleasure to issue you with the enclosed Certificate of Suitability EESS-220756-0.

Please check and ensure the details are correct in accordance with your application.

The Certificate Lock Password will be advised once payment has been received. The Responsible Supplier or their Authorised Representative is still required to register their equipment on the National Database as part of the EESS.

We remind you that the Regulatory Compliance Mark (RCM) must be used in accordance with its conditions of use as set out in the latest edition of [AS/NZS 4417.1](#).

Please note that as certification is based on type testing, modification to the electrical equipment in any way must be notified to EESS Conformity Certification for certification. Details of the modification may be advised by completing and submitting the application online via our Online Application System (OAS) with your login credentials.


Any change to the name or address of the holder of the certificate must be notified to EESS Conformity Certification within one calendar month. Changes may be advised by completing and submitting the application online via our Online Application System (OAS) with your login credentials.

An application for the transfer of the Certificate from the existing Certificate Holder to another Holder may be made to EESS Conformity Certification by completing and submitting the application online via our Online Application System (OAS) with your login credentials.

Finally, please use the QR code below to take the two-minute survey and comment on our service.

Should you have any further queries, please contact the undersigned.

Yours sincerely,



For and on behalf of
Conformity Certification Services Pty Ltd



We'd love to know what you thought of our service. Please scan to fill in a brief survey or visit www.eessconformity.com



Certificate No.: EESS-220756-0

CERTIFICATE OF SUITABILITY

Certificate Holder: Univolt Extrusions (Dongguan) Limited
Dongshan Yongfa Industrial Area, Qi Shi Town
Dongguan, Guangdong, 523511
CHINA

Regulatory Definition: Non-declared/ Out of Scope
Product Type: Pliable non-metallic conduits for cable management (PVC Corrugated conduits for cable management)
Trade Name: Univolt
Model No(s): Grey (Medium duty): 9016TCM 16 3331, 9020TCM 20 3331, 9025TCM 25 3331, 9032TCM 32 3331 (16/20/25/32mm)
Red (Heavy duty): 9020CHD 4431, 9025CHD 4431, 9032CHD 4431 (20/25/32mm)
Ratings: Non-threadable, non-flame propagating, IP30, Ambient Max 60 °C.
Standard(s): AS/NZS 61386.22:2015 with IEC 61386.1:2008
Conditions: Indoor use.

Required marking: The Regulatory Compliance Mark (RCM) in accordance with its conditions of use as set out in the latest edition of AS/NZS 4417.1.

Date of Issue: 6 October 2022
Valid until: 5 October 2027

Conformity Certification Services Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies that the Electrical Equipment as described on this certificate complies with the minimum essential safety requirements for which the application has been made.

For and on behalf of
Conformity Certification Services Pty Ltd
trading as EESS Conformity Certification