

# Certificate of Suitability

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the Certificate number and Regulatory Compliance Mark (RCM) mark on the product of the same type provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the Certificate number and/or RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein.

## CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	<b>Schneider Electric (Australia) Pty Ltd</b>	Other Name	<b>CLIPSAL</b>
Address	<b>33-37 Port Wakefield Road Gepps Cross SA 5094 Australia</b>		
Client ID	<b>102093</b>	Global-Mark File Number:	<b>102093-310</b>
Certification and Authorized Mark Number	<b>GMA-510657</b>	Revision Number	<b>00</b>
Certification Standard(s)	<b>AS 60947.3:2018 Low-voltage switchgear and controlgear Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units</b>		
Type of Certification	<b>Electrical Safety Product</b> <i>Scheme</i> <b>Global-Mark Electrical Product Safety Certification Scheme</b>		
			System 1 Approval

## CERTIFICATE DATES

Certificate Issue Date	<b>19/06/2023</b>
Certificate Last Update Date	
Certification Expiry Date	<b>19/06/2028</b>

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



**Certification Manager**



# Certificate of Suitability

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Non declared	Surface Switches - Standard Range In Standard Enclosures - 1-Pole	Clipsal	56SW150	250 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 1-Pole - Less Enclosure	Clipsal	56SW150LE	250 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 1-Pole	Clipsal	56SW163	250 Va.c., 63A, M300 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 1-Pole - Less Enclosure	Clipsal	56SW163LE	250 Va.c., 63A, M300 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 2-Pole	Clipsal	56SW250	250 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 2-Pole - Less Enclosure	Clipsal	56SW250LE	250 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 2-Pole	Clipsal	56SW263	250 Va.c., 63A, M300 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 2-Pole - Less Enclosure	Clipsal	56SW263LE	250 Va.c., 63A, M300 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole	Clipsal	56SW350	500 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole - Less Enclosure	Clipsal	56SW350LE	500 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-pole, 2-gang	Clipsal	56SW363/2	500 Va.c., 63A, M300 , IP66

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



**Certification Manager**






global-mark®

# Certificate of Suitability

Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-pole, 2-gang - Less Enclosure	Clipsal	56SW363/2LE	500 Va.c., 63A, M300 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole	Clipsal	56SW363	500 Va.c., 63A, M300 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole - Less Enclosure	Clipsal	56SW363LE	500 Va.c., 63A, M300 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 1-Pole	PDL	56SW150	250 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 1-Pole - Less Enclosure	PDL	56SW150LE	250 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 2-Pole	PDL	56SW250	250 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 2-Pole - Less Enclosure	PDL	56SW250LE	250 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole	PDL	56SW340	500 Va.c., 40A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole - Less Enclosure	PDL	56SW340LE	500 Va.c., 40A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole	PDL	56SW3502	500 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole - Less Enclosure	PDL	56SW3502LE	500 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole	PDL	56SW350	500 Va.c., 50A, M250 , IP66

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



Certification Manager



JAS-ANZ



# Certificate of Suitability

Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole - Less Enclosure	PDL	56SW350LE	500 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole	PDL	56SW3632	500 Va.c., 63A, M300 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole, 2-Gang-Less Enclosure	PDL	56SW3632LE	500 Va.c., 63A, M300 , IP66
Non declared	Surface Switch, Key Lock range, in Standard Enclosures, 3-pole for Locking in Only The 'OFF' Position	PDL	56SWK350	500 Va.c., 50A, M250 , IP66
Non declared	Surface Switch, Key Lock range, in Standard Enclosures, 3-pole for Locking in Only The 'OFF' Position - Less Enclosure	PDL	56SWK350LE	500 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 1-Pole	Schneider Electric	56SW250	250 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole	Schneider Electric	56SW350	500 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole - Less Enclosure	Schneider Electric	56SW350LE	500 Va.c., 50A, M250 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole	Schneider Electric	56SW363	500 Va.c., 63A, M300 , IP66
Non declared	Surface Switches - Standard Range In Standard Enclosures - 3-Pole - Less Enclosure	Schneider Electric	56SW363LE	500 Va.c., 63A, M300 , IP66

**RELEVANT TRADEMARK (S)**

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.


**Certification Manager**


# Certificate of Suitability

--

COMMENTS OR CONDITIONS ON THE CERTIFICATION
Nil

End of document



This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



Certification Manager

