

Certificate of Suitability

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the Certificate number and Regulatory Compliance Mark (RCM) mark on the product of the same type provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the Certificate number and/or RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein.

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	Schneider Electric (Australia) Pty Ltd	Other Name	
Address	33-37 Port Wakefield Road Gepps Cross SA 5094 Australia		
Client ID	102093	Global-Mark File Number:	102093-400
Certification and Authorized Mark Number	GMA-524924	Revision Number	00
Certification Standard(s)	AS 3133:2020 Amd 1: 2024 & AS/NZS 3100:2022 Amd 1: 2023, Amd 2: 2024 Approval and test specification - Air-break switches		
Type of Certification	Electrical Safety Product	Scheme	Global-Mark Electrical Product Safety Certification Scheme
			System 1 Approval

CERTIFICATE DATES

Certificate Issue Date	7/10/2025
Certificate Last Update Date	
Certification Expiry Date	7/10/2030

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager




Certificate of Suitability

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Non declared	Wilco ROWCO, Metal Clad Reversing Switch 3 Pole	CLIPSAL	WMS332R	415V~, 50Hz, 32A, IP66, AC-23A: 11kW, AC-21A: 32A

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION
2025/10/07 Initial Certification - complies with AS 3133:2020+A1:2024 AC-23A and AC-21A comply with AS 60947.3:2023

End of document

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.



Certification Manager


