Certificate of Suitability

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the Certificate number and Regulatory Compliance Mark (RCM) mark on the product of the same type provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the Certificate number and/or RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein.

CERTIFICATION AND CERTIFICATE HOLDER DETAILS			
Company Name	**Schneider Electric (Australia) Pty Ltd**	Other Name	
Address	**33-37 Port Wakefield Road Gepps Cross SA 5094 Australia**		
Client ID	**102093**	Global-Mark File Number: **102093-411**	System 1 Approval
Certification and Authorized Mark Number	**GMA-526425**	Revision Number **01**	
Certification Standard(s)	**AS 60947.3:2023 Low-voltage switchgear and controlgear Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units**		
Type of Certification	**Electrical Safety Product**	*Scheme* **Global-Mark Electrical Product Safety Certification Scheme**	

CERTIFICATE DATES	
Certificate Issue Date	**20/12/2025**
Certificate Last Update Date	**8/01/2026**
Certification Expiry Date	**20/12/2030**

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.

Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia

Certificate of Suitability

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	**Product Description**	**Trade Name**	**Model Number**	**Rating**
Non declared	WilcoROWCO Metal Clad Switch 3 pole	CLIPSAL	WMS350	415Vac, 50Hz, 50A, AC-23A: 18.5kW, AC-21A: 50A; IP66, Suitable for Isolation
Non declared	WilcoROWCO Metal Clad Switch 3 pole	CLIPSAL	WMS363	415Vac, 50Hz, 63A, AC-23A: 22kW, AC-21A: 63A; IP66, Suitable for Isolation
Non declared	WilcoROWCO Metal Clad Switch 3 pole	CLIPSAL	WMS380	415Vac, 50Hz, 80A, AC-23A: 30kW (55A), AC-21A: 80A; IP66, Suitable for Isolation
Non declared	WilcoROWCO Metal Clad Switch 4 pole	CLIPSAL	WMS450	415Vac, 50Hz, 50A, AC-23A: 22kW, AC-21A: 50A; IP66, Suitable for Isolation
Non declared	WilcoROWCO Metal Clad Switch 4 pole	CLIPSAL	WMS463	415Vac, 50Hz, 63A, AC-23A: 22kW (40A), AC-21A: 63A; IP66, Suitable for Isolation
Non declared	WilcoROWCO Metal Clad Switch 6 pole	CLIPSAL	WMS663	415Vac, 50Hz, 63A, AC-23A: 22kW (40A), AC-21A: 63A; IP66, Suitable for Isolation

RELEVANT TRADEMARK (S)

COMMENTS OR CONDITIONS ON THE CERTIFICATION
2025/12/20 Initial Certification Nil 2026/01/08 Modification 1 Reissue as JASANZ certificate

End of document

This certification remains valid until the above-mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jasanz.org/register for verification.

Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia