

Australia and New Zealand Certificate of Suitability

Certificate
ULL-104136

Issue date
2025-09-19

Expiration date
2030-09-19



www.jasanz.org/register

This is to acknowledge that

SCHNEIDER ELECTRIC AUSTRALIA PTY LTD

33-37 PORT WAKEFIELD RD, GEPPS CROSS, South Australia 5094
Australia

has had


Isolating Switch

[refer following page(s) for models list]

evaluated and meets the requirements of the standard(s)

**AS 3133:2020, Amd 1:2024; AS/NZS 3100:2022,
Amd 1: 2023, Amd 2: 2024**

Certificate of Suitability issued under Queensland Government's
Recognised External Certification Scheme (RECS)
ANZ Certification Scheme requirements.



Amarjit Singh (Certification Officer)

Certification Body:
UL International New Zealand Limited,
54 Tarnedale Grove, Albany, Auckland 0632, New Zealand.

Issued for use in Australia and New Zealand only.
All dates are in Year-Month-Day format (YYYY-MM-DD).

Australia and New Zealand Certificate of Suitability

Certificate No: ULL-104136

Date of Issue/Revision: 2025-09-19

Trade Name or Trademark: CLIPSAL

Risk Class / NSW Declared Class: LEVEL 1 - Non-prescribed / non-declared

IEC Standard Country Differences: Not applicable

Certification Marking: The RCM mark must be applied to the product and all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.

Additional Certification Conditions: None.

Model Details:

Model Name
WHA135

Additional Information:

Rating: 250V a.c., 35A, M160, single pole, IP66.

Additional requirements of AS 3133 APPENDIX A (Additional Requirements for Isolating Switches) were also addressed.