

Australia and New Zealand Certificate of Suitability

Certificate
ULL-104488

Issue date
2026-10-02

Expiration date
2031-10-02



www.jasanz.org/register

This is to acknowledge that

SCHNEIDER ELECTRIC AUSTRALIA PTY LTD

33-37 PORT WAKEFIELD RD, GEPPS CROSS, South Australia 5094
Australia

has had

Fan controller mechanism

[refer following page(s) for models list]

evaluated and meets the requirements of the standard(s)

AS 60669.2.1:2020; AS/NZS 60669.1:2020, Amd 1:2022

Certificate of Suitability issued under Queensland Government's
Recognised External Certification Scheme (RECS)
ANZ Certification Scheme requirements.

Amarjit Singh (Certification Officer)

Certification Body:
UL International New Zealand Limited,
54 Tarndale Grove, Albany, Auckland 0632, New Zealand.

Issued for use in Australia and New Zealand only.
All dates are in Year-Month-Day format (YYYY-MM-DD).

Australia and New Zealand Certificate of Suitability

Certificate No: ULL-104488

Date of Issue/Revision: 2026-10-02

Trade Name or Trademark: CLIPSAL

Risk Class / NSW Declared Class: LEVEL 1 - Non-prescribed / non-declared

IEC Standard Country Differences: AU and NZ

Certification Marking: The RCM mark must be applied to the product and all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.

Additional Certification Conditions: Product is a component for building in. 3 A external circuit protection required.

Model Details:

Model Name
32E500FM

Additional Information:

Rating: 220-240 V~, 50 Hz, 40 W min load, 500 W max load.
for small motor loads (ceiling fans, exhaust fans).