

Australia and New Zealand Certificate of Suitability

Certificate
ULL-104494

Issue date
2026-05-12

Expiration date
2031-05-12



www.jasanz.org/register

This is to acknowledge that

SCHNEIDER ELECTRIC AUSTRALIA PTY LTD

33-37 PORT WAKEFIELD RD, GEPPS CROSS, South Australia 5094
Australia

has had

Air-break switch

[refer following page(s) for models list]

evaluated and meets the requirements of the standard(s)

AS/NZS 60669.1:2020, Amd 1:2022

Certificate of Suitability issued under Queensland Government's
Recognised External Certification Scheme (RECS)
ANZ Certification Scheme requirements.



Stuart Foster (Certification Officer)

Certification Body:
UL International New Zealand Limited,
54 Tarndale Grove, Albany, Auckland 0632, New Zealand.

Issued for use in Australia and New Zealand only.
All dates are in Year-Month-Day format (YYYY-MM-DD).

Australia and New Zealand Certificate of Suitability

Certificate No: ULL-104494

Date of Issue/Revision: 2026-05-12

Trade Name or Trademark: CLIPSAL: 40M32, CLIPSAL: 40M32COOK, CLIPSAL: P40M32COOK, PDL: PDL380M32, PDL: PDLP380M32O, PDL: PDLP380M32HOB

Risk Class / NSW Declared Class: LEVEL 1 - Non-prescribed / non-declared

IEC Standard Country Differences: AU and NZ

Certification Marking: The RCM mark must be applied to the product and all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.

Additional Certification Conditions: None.

Model Details:

Model Name
40M32
40M32COOK
P40M32COOK
PDL380M32
PDLP380M32O
PDLP380M32HOB

Additional Information:

Rating : 250 Vac, 32 A, M100

Certified Air-Break Switch to be used with Iconic series and Pro Series wall plates.