Ref. Certif. No.
BE-8267

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Isolating switches
Name and address of the applicant	Schneider Electric Industries SAS 31, rue Pierre Mendès France, Eybens 38050 GRENOBLE CEDEX 09 France
Name and address of the manufacturer	Schneider Electric Industries SAS 31, rue Pierre Mendès France, Eybens 38050 GRENOBLE CEDEX 09 France
Name and address of the factory Note: *When more than one factory, please report on page 2*	☐ Additional information on page 2 Schneider Electric NV/SA Dieweg 3 1180 BRUSSEL Belgium
Ratings and principal characteristics	See Appendix 1
Trademark (if any)	SCHNEIDER ELECTRIC
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	R9S64363 & R9S64463
Additional information (if necessary may also be reported on page 2)	☐ Additional information on page 2 -
A sample of the product was tested and found to be in conformity with	IEC 60669-2-4:2004
As shown in the Test Report Ref. No. which forms part of this Certificate	58293208/01 and 58293207/01 up to 58293207/06 and 58293204/01 up to 58293204/03

This CB Test Certificate is issued by the National Certification Body

SGS Belgium N.V. - Division SGS-CEBEC
Business Riverside Park, Avenue Internationalelaan 55 Build. D, BE-1070 BRUSSEL,
Belgium

Date: 2018-05-28

Signature: Calogero Lana

Ratings:

number of poles	:	3 P & 4 P
rated voltage (Un)	:	415 Vac
rated current (In)	:	63 A
utilization category	:	AC22A
rated insulation voltage (Ui)	:	500 V
rated impulse withstand voltage (Uimp)	:	6 kV under frame
rated conditional short-circuit current	:	6 kA
rated frequency	:	50 Hz / 60 Hz
SCPD	:	Silver Wire
degree of protection	:	IP 40 under frame / IP 20
method of application	:	semi flush-type, DIN rail
terminals	:	screw-type