Ref. Certif. No.

SE-112044

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)
Name and address of the applicant	Schneider Electric Industries SAS 35 rue Joseph Monier 92500 Rueil-Malmaison, France
Name and address of the manufacturer	Same as applicant
Name and address of the factory Note: *When more than one factory, please report on page 2*	Schneider (Thailand) Limited 540 Soi 9 Bangpoo Industrial Estate, Sukhumvit Road, Muang District, Samutprakarn 10280, Thailand ☐ Additional Information on page 2
Ratings and principal characteristics	See page 2
Trademark / Brand (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	QOvs
Additional information (if necessary may also be reported on page 2)	☒ Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61009-1:2010+A1+A2 IEC 61009-2-2:1991
As shown in the Test Report Ref. No. which forms part of this Certificate	230201286SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 11 September, 2023

intertek

Signature:

Fredrik Wennersten

Rating and principal characteristics

Un= 230/240V~(1P+N), 50/60Hz;
In= 6, 10, 16, 20, 25, 32, 40, 50A, B- & C- type;
I∆n= 10, 30, 100mA, type -A & -AC;
Icn= 10000A, Ics= 7500A;
Icn= Ics= 6000A;
Ref. temperature 40°C, Energy limiting class 3.

Additional information

The products have also been checked according to:
AS/NZS 61009.1:2015
EN 61009-1:2012+A1+A2+A11+A12+A13
BS EN 61009-1:2012+A13

Date: 11 September, 2023

Signature: