



CCA Statement of Test Results (STR)

030/ES0147-M1-AENOR

AENOR states that by request of:

SCHNEIDER ELECTRIC INDUSTRIES SAS

registered office 35, RUE JOSEPH MONIER RUEIL MALMAISON CEDEX (Francia)

a sample of the product **Residual current operated circuit-breaker without integral overcurrent protection (RCCB's)**

has been tested and found to be in conformity with the standards

UNE-EN 61008-1:2013 (EN 61008-1:2012)
UNE-EN 61008-1:2013/A1:2015 (EN 61008-1:2012/A1:2014)
UNE-EN 61008-1:2013/A2:2015 (EN 61008-1:2012/A2:2014)
UNE-EN 61008-1:2013/A11:2016 (EN 61008-1:2012/A11:2015)
UNE-EN 61008-1:2013/A12:2017 (EN 61008-1:2012/A12:2017)
UNE-EN 61008-2-1:1996 (EN 61008-2-1:1994)
UNE-EN 61008-2-1/A11:1999 (EN 61008-2-1:1994/A11:1998)

Test reports GS268/17 to GS292/17 (Head Report), GS188/20 to GS241/20 + GS323/20 (Head Report),

References Specified in Annex to the Certificate

Production site Camino BARRANQUET, 57 46133 MELIANA (Valencia/València - España)

Certification scheme This Statement of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This Statement of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as revised on March 29th, 1983 and September 3rd, 2004. Any other body participating in the CCA may recognize this Statement as a basis for granting a national mark of conformity or a national approval as specified in OD 6, List of current decisions of CCA Group, point 2.11.

This certificate supersedes 030/ES0147, dated 2021-11-04

First issued on 2024-04-29

Rafael GARCÍA MEIRO
CEO



General

AENOR CONFÍA S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com



CCA Statement of Test Results (STR)

030/ES0147-M1-AENOR

Annex to Certificate

Trade mark: SCHNEIDER ELECTRIC

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual current	Freq uency	IΔm	I _m	Inc	IΔc	Type	Additional information
iID2P100A100mA	2	100A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID2P100A100AAC	2	100A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P100A100AACs	2	100A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID2P100A100mAAS	2	100A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID2P100A100mAASI	2	100A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P100A100mAASIS	2	100A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID2P100A30mA	2	100A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID2P100A30AAC	2	100A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID2P100A30mAASI	2	100A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3)
iID2P100A300mA	2	100A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID2P100A300AAC	2	100A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID2P100A300AACs	2	100A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID2P100A300mAAS	2	100A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1) (3)
iID2P100A300mAASI	2	100A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P100A300mAASIS	2	100A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1) (3)
iID2P100A500mAAC	2	100A	230V	500mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P16A10mA	2	16A	230V	10mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID2P16A10AAC	2	16A	230V	10mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P16A10mAASI	2	16A	230V	10mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P16A100mA	2	16A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID2P16A100AAC	2	16A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P16A100AACs	2	16A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID2P16A100mAAS	2	16A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID2P16A100mAASI	2	16A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P16A100mAASIS	2	16A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID2P16A30mA	2	16A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID2P16A30AAC	2	16A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P16A30mAASI	2	16A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3)
iID2P16A300mA	2	16A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID2P16A300AAC	2	16A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P16A300AACs	2	16A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID2P16A300mAAS	2	16A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1) (3)
iID2P16A300mAASI	2	16A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P16A300mAASIS	2	16A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1) (3)
iID2P16A500mAAC	2	16A	230V	500mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P25A10mA	2	25A	230V	10mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (4)
iID2P25A10AAC	2	25A	230V	10mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID2P25A10mAASI	2	25A	230V	10mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P25A100mA	2	25A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	A	(1)

General

First issued on 2024-04-29



AENOR CONFÍA S.A.U.
 Génova, 6. 28004 Madrid. España
 Tel. 91 432 60 00.- www.aenor.com



CCA Statement of Test Results (STR)

030/ES0147-M1-AENOR

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual current	Freq uency	IΔm	Im	Inc	IΔc	Type	Additional information
iID2P25A100mAAC	2	25A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P25A100mAACS	2	25A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID2P25A100mAAS	2	25A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID2P25A100mAASI	2	25A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P25A100mAASIS	2	25A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID2P25A30mAAC-VB	2	25A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID2P25A30mAASI-VB	2	25A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3) (5)
iID2P25A30mAA-VB	2	25A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3) (4)
iID2P25A300mAA	2	25A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3) (4)
iID2P25A300mAAC	2	25A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P25A300mAACS	2	25A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID2P25A300mAAS	2	25A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1) (3)
iID2P25A300mAASI	2	25A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P25A300mAASIS	2	25A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1) (3)
iID2P25A500mAA	2	25A	230V	500mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P40A100mAA	2	40A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID2P40A100mAAC	2	40A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID2P40A100mAACS	2	40A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID2P40A100mAAS	2	40A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID2P40A100mAASI	2	40A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P40A100mAASIS	2	40A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID2P40A30mAAC-VB	2	40A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID2P40A30mAASI-VB	2	40A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3) (5)
iID2P40A30mAA-VB	2	40A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3) (4)
iID2P40A300mAA	2	40A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3) (4)
iID2P40A300mAAC	2	40A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID2P40A300mAACS	2	40A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID2P40A300mAAS	2	40A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1) (3) (4)
iID2P40A300mAASI	2	40A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P40A300mAASIS	2	40A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1) (3)
iID2P40A500mAAC	2	40A	230V	500mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P63A100mAA	2	63A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID2P63A100mAAC	2	63A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID2P63A100mAACS	2	63A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID2P63A100mAAAS	2	63A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID2P63A100mAASI	2	63A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P63A100mAASIS	2	63A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID2P63A30mAAC-VB	2	63A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID2P63A30mAASI-VB	2	63A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3) (5)
iID2P63A30mAA-VB	2	63A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID2P63A30mAA-VC	2	63A	110V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1)

General

First issued on 2024-04-29



AENOR CONFÍA S.A.U.
 Génova, 6. 28004 Madrid. España
 Tel. 91 432 60 00.- www.aenor.com



CCA Statement of Test Results (STR)

030/ES0147-M1-AENOR

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual current	Freq uency	IΔm	Im	Inc	IΔc	Type	Additional information
iID2P63A300mAA	2	63A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID2P63A300mAAC	2	63A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID2P63A300mAACS	2	63A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID2P63A300mAAS	2	63A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1) (3)
iID2P63A300mAASI	2	63A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P63A300mAASIS	2	63A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1) (3)
iID2P63A500mAAC	2	63A	230V	500mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P80A100mAA	2	80A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID2P80A100mAAC	2	80A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID2P80A100mAACS	2	80A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID2P80A100mAAS	2	80A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID2P80A100mAASI	2	80A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P80A100mAASIS	2	80A	230V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID2P80A30mAA	2	80A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID2P80A30mAAC-VB	2	80A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID2P80A30mAASI	2	80A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3)
iID2P80A300mAA	2	80A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID2P80A300mAAC	2	80A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID2P80A300mAACS	2	80A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID2P80A300mAAS	2	80A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1) (3)
iID2P80A300mAASI	2	80A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID2P80A300mAASIS	2	80A	230V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1) (3)
iID2P80A500mAAC	2	80A	230V	500mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID4P100A100mAA	4	100A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID4P100A100mAAC	4	100A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID4P100A100mAACS	4	100A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P100A100mAAS	4	100A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID4P100A100mAASI	4	100A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID4P100A100mAASIS	4	100A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID4P100A30mAA	4	100A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID4P100A30mAAC-VB	4	100A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID4P100A30mAASI	4	100A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3) (5)
iID4P100A300mAA	4	100A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID4P100A300mAAC	4	100A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID4P100A300mAACS	4	100A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P100A300mAAS	4	100A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1) (3)
iID4P100A300mAASI	4	100A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3)
iID4P100A300mAASIS	4	100A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1) (3)
iID4P100A500mAA	4	100A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID4P100A500mAAC	4	100A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID4P100A500mAACS	4	100A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)

General

First issued on 2024-04-29



AENOR CONFÍA S.A.U.
 Génova, 6. 28004 Madrid. España
 Tel. 91 432 60 00.- www.aenor.com



CCA Statement of Test Results (STR)

030/ES0147-M1-AENOR

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual current	Freq uency	IΔm	I _m	Inc	IΔc	Type	Additional information
iID4P100A500mAAS	4	100A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID4P100A500mAASI	4	100A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID4P100A500mAASIS	4	100A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID4P25A100mAA	4	25A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID4P25A100mAAC	4	25A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID4P25A100mAACS	4	25A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P25A100mAAS	4	25A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID4P25A100mAASI	4	25A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID4P25A100mAASIS	4	25A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID4P25A30mAAC-VB	4	25A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID4P25A30mAASI-VB	4	25A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3) (5)
iID4P25A30mAA-VB	4	25A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3) (4)
iID4P25A300mAA	4	25A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3) (4)
iID4P25A300mAAC	4	25A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID4P25A300mAACS	4	25A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P25A300mAAS	4	25A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1) (3)
iID4P25A300mAASI	4	25A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3)
iID4P25A300mAASIS	4	25A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1) (3)
iID4P25A500mAA	4	25A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID4P25A500mAAC	4	25A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID4P25A500mAACS	4	25A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P25A500mAAS	4	25A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID4P25A500mAASI	4	25A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID4P25A500mAASIS	4	25A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID4P40A100mAA	4	40A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID4P40A100mAAC	4	40A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID4P40A100mAACS	4	40A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P40A100mAAS	4	40A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1) (4)
iID4P40A100mAASI	4	40A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID4P40A100mAASIS	4	40A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID4P40A30mAAC-VB	4	40A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID4P40A30mAASI-VB	4	40A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3) (5)
iID4P40A30mAA-VB	4	40A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3) (4)
iID4P40A300mAA	4	40A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3) (4)
iID4P40A300mAAC	4	40A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID4P40A300mAACS	4	40A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P40A300mAAS	4	40A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1) (3) (4)
iID4P40A300mAASI	4	40A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3)
iID4P40A300mAASIS	4	40A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1) (3)
iID4P40A500mAA	4	40A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID4P40A500mAAC	4	40A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)

General

First issued on 2024-04-29



AENOR CONFÍA S.A.U.
 Génova, 6. 28004 Madrid. España
 Tel. 91 432 60 00.- www.aenor.com



CCA Statement of Test Results (STR)

030/ES0147-M1-AENOR

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual current	Freq uency	IΔm	Im	Inc	IΔc	Type	Additional information
iID4P40A500mAACS	4	40A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P40A500mAAS	4	40A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID4P40A500mAASI	4	40A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID4P40A500mAASIS	4	40A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID4P63A100mAA	4	63A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID4P63A100mAAC	4	63A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID4P63A100mAACS	4	63A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P63A100mAAS	4	63A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID4P63A100mAASI	4	63A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID4P63A100mAASIS	4	63A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID4P63A30mAAC-VB	4	63A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID4P63A30mAASI-VB	4	63A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3) (5)
iID4P63A30mAA-VB	4	63A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID4P63A30mAA-VC	4	63A	230V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID4P63A30mAA	4	63A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID4P63A300mAAC	4	63A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID4P63A300mAACS	4	63A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P63A300mAAS	4	63A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1) (3)
iID4P63A300mAASI	4	63A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3)
iID4P63A300mAASIS	4	63A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1) (3)
iID4P63A500mAA	4	63A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID4P63A500mAAC	4	63A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID4P63A500mAACS	4	63A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P63A500mAAS	4	63A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID4P63A500mAASI	4	63A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID4P63A500mAASIS	4	63A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID4P80A100mAA	4	80A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID4P80A100mAAC	4	80A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID4P80A100mAACS	4	80A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P80A100mAAS	4	80A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID4P80A100mAASI	4	80A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID4P80A100mAASIS	4	80A	400V	100mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iID4P80A30mAA	4	80A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID4P80A30mAAC-VB	4	80A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID4P80A30mAASI	4	80A	400V	30mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3) (5)
iID4P80A300mAA	4	80A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	A	(1) (3)
iID4P80A300mAAC	4	80A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	AC	(1) (5)
iID4P80A300mAACS	4	80A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P80A300mAAS	4	80A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1) (3)
iID4P80A300mAASI	4	80A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1) (3)
iID4P80A300mAASIS	4	80A	400V	300mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1) (3)

General

First issued on 2024-04-29



AENOR CONFÍA S.A.U.
 Génova, 6. 28004 Madrid. España
 Tel. 91 432 60 00.- www.aenor.com



CCA Statement of Test Results (STR)

030/ES0147-M1-AENOR

Annex to Certificate

Type Ref.	No. of poles	Rated current	Rated voltage	Rated residual current	Freq uency	IΔm	I _m	Inc	IΔc	Type	Additional information
iID4P80A500mAA	4	80A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	A	(1)
iID4P80A500mAAC	4	80A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	AC	(1)
iID4P80A500mAACS	4	80A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	AC-S	(1)
iID4P80A500mAAS	4	80A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	A-S	(1)
iID4P80A500mAASI	4	80A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	Asi	(1)
iID4P80A500mAASIS	4	80A	400V	500mA	50Hz	1500A	1500A	10kA	10kA	Asi-S	(1)
iIDK4P25A30mAAC	4	25A	400V	30mA	50Hz	500A	500A	4,5kA	4,5kA	AC	(2)
iIDK4P25A30mAAC-VB	4	25A	400V	30mA	50Hz	500A	500A	4,5kA	4,5kA	AC	(1)
iIDK4P25A300mAAC	4	25A	400V	300mA	50Hz	500A	500A	4,5kA	4,5kA	AC	(1)
iIDK4P40A30mAAC	4	40A	400V	30mA	50Hz	500A	500A	4,5kA	4,5kA	AC	(2)
iIDK4P40A30mAAC-VB	4	40A	400V	30mA	50Hz	500A	500A	4,5kA	4,5kA	AC	(1)
iIDK4P40A300mAAC	4	40A	400V	300mA	50Hz	500A	500A	4,5kA	4,5kA	AC	(1)
iIDK4P63A30mAAC	4	63A	400V	30mA	50Hz	500A	500A	4,5kA	4,5kA	AC	(2)
iIDK4P63A30mAAC-VB	4	63A	400V	30mA	50Hz	500A	500A	4,5kA	4,5kA	AC	(1)
iIDK4P63A300mAAC	4	63A	400V	300mA	50Hz	500A	500A	4,5kA	4,5kA	AC	(1)

Remarks:

- (1) Test Sequence according to IEC 61008-1:2010 + A1:2012 + A2:2013; IEC 61008-2-1:1990; EN 61008-1:2012 + A1:2014 + A2:2014; EN 61008-2-1:1994 + A11:1998
- (2) Test Sequence according to IEC 61008-1:2010 + A1:2012 + A2:2013; IEC 61008-2-1:1990
- (3) Test Sequence according to AS/NZS 61008.1:2015 for Australia and New Zealand
- (4) Test sequence according to EN 61008-1:2012/A12:2017, Belgium deviation.
- (5) Test sequence according to GB/T 16916.1 requirement for Chinese CCC marking

General

First issued on 2024-04-29



AENOR CONFÍA S.A.U.
 Génova, 6. 28004 Madrid. España
 Tel. 91 432 60 00.- www.aenor.com