



Certificate of Conformity

This is to certify that OFFICE OF THE TECHNICAL REGULATOR has, in accordance with the Regulation 4 of the Energy Products (Safety and Efficiency) Regulations 2012, approved the electrical equipment described here under.

Certificate holder business name SCHNEIDER ELECTRIC (AUSTRALIA) PTY LIMITED

Certificate holder trade name SCHNEIDER ELECTRIC AUST PTY LIMITED

Certificate holder address 2 Banfield Road,
Macquarie Park, New South Wales, 2113

Equipment level Level3

Equipment class Residual current device

Equipment sub-class

Generic name of equipment 4RCBE & RCBE & A9D & DOM series

Date first issued 13/12/2022

Date of expiry 13/12/2027

Condition of certification

Regulatory body Office of the Technical Regulator

Delegated signatory

A handwritten signature in blue ink that reads 'George Nestic'.

George Nestic
Approvals Officer



Regulatory details

Marking *



Relevant standards

AS/NZS 61009.1 2015

Compliant to Australia and New Zealand standards

* Electrical equipment covered by this certificate must comply in all respects with the certified article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by OFFICE OF THE TECHNICAL REGULATOR (OTR) prior to the equipment being supplied or offered for supply.

Notification must be given to OFFICE OF THE TECHNICAL REGULATOR (OTR) of any change to the name or address of the holder of the certificate within 20 business days.

Equipment

Equipment family details

Protection against electric shock

Type of attachment fixed wired

Type of fixing fixed

Additional family details

Equipment Profiles

Equipment Profile 1



Model	Trade name
4RCBE206/30S	CLIPSAL
4RCBE210/30S	CLIPSAL
4RCBE216/30S	CLIPSAL
4RCBE220/30S	CLIPSAL
4RCBE225/30S	CLIPSAL
4RCBE232/30S	CLIPSAL

Input 230/240 V, 50 Hz, 6A, 10A, 16A, 20A, 25A, 32A

Nameplate

Product example

Degree of protection IP

Short circuit rating 6kA

Current leakage rating 30mA

Overcurrent curve C-curve

RCD Type Type A

Other

Equipment Profile 2

Model	Trade name
4RCBE206/10S	CLIPSAL
4RCBE210/10S	CLIPSAL
4RCBE216/10S	CLIPSAL
4RCBE220/10S	CLIPSAL
4RCBE225/10S	CLIPSAL
4RCBE232/10S	CLIPSAL

Input 230/240 V, 50 Hz, 6A, 10A, 16A, 20A, 25A, 32A

Nameplate

Product example

Certificate no. OTR220031

Uncontrolled Copy - Go to ees.gov.au to verify the particulars of this certificate



**Government
of South Australia**

Department for
Energy and Mining

Degree of protection	IP
Short circuit rating	6kA
Current leakage rating	10mA
Overcurrent curve	C-curve
RCD Type	Type A
Other	

Equipment Profile 3

Model	Trade name
RCBE206/30S	CLIPSAL
RCBE210/30S	CLIPSAL
RCBE216/30S	CLIPSAL
RCBE220/30S	CLIPSAL
RCBE225/30S	CLIPSAL
RCBE232/30S	CLIPSAL

Input 230/240 V, 50 Hz, 6A, 10A, 16A, 20A, 25A, 32A

Nameplate

Product example

Degree of protection	IP
Short circuit rating	4.5kA
Current leakage rating	30mA
Overcurrent curve	C-curve
RCD Type	Type A
Other	

Equipment Profile 4



Model	Trade name
A9D73606	SCHNEIDER ELECTRIC
A9D73610	SCHNEIDER ELECTRIC
A9D73616	SCHNEIDER ELECTRIC
A9D73620	SCHNEIDER ELECTRIC
A9D73625	SCHNEIDER ELECTRIC
A9D73632	SCHNEIDER ELECTRIC

Input 230/240 V, 50 Hz, 6A, 10A, 16A, 20A, 25A, 32A

Nameplate

Product example

Degree of protection IP

Short circuit rating 6kA

Current leakage rating 30mA

Overcurrent curve C-curve

RCD Type Type A

Other

Equipment Profile 5

Model	Trade name
A9D40606	SCHNEIDER ELECTRIC
A9D40610	SCHNEIDER ELECTRIC
A9D40616	SCHNEIDER ELECTRIC
A9D40620	SCHNEIDER ELECTRIC
A9D40625	SCHNEIDER ELECTRIC
A9D40632	SCHNEIDER ELECTRIC

Input 230/240 V, 50 Hz, 6A, 10A, 16A, 20A, 25A, 32A

Nameplate

Product example



Degree of protection	IP
Short circuit rating	6kA
Current leakage rating	10mA
Overcurrent curve	C-curve
RCD Type	Type A
Other	

Equipment Profile 6

Model	Trade name
DOM12529	SCHNEIDER ELECTRIC NZ
DOM12530	SCHNEIDER ELECTRIC NZ
DOM12531	SCHNEIDER ELECTRIC NZ
DOM12532	SCHNEIDER ELECTRIC NZ
DOM12533	SCHNEIDER ELECTRIC NZ
DOM12534	SCHNEIDER ELECTRIC NZ

Input	230/240 V, 50 Hz, 6A, 10A, 16A, 20A, 25A, 32A
Nameplate	
Product example	
Degree of protection	IP
Short circuit rating	6kA
Current leakage rating	30mA
Overcurrent curve	C-curve
RCD Type	Type A
Other	



Certificate no. OTR220031
Uncontrolled Copy - Go to ees.gov.au to
verify the particulars of this certificate



**Government
of South Australia**

Department for
Energy and Mining

Nameplates

Product examples

Certificate no. OTR220031

Uncontrolled Copy - Go to ees.gov.au to
verify the particulars of this certificate



**Government
of South Australia**

Department for
Energy and Mining

History of certificate

OTR220031/00 (New)

13 December, 2022

Certificate for Residual current device issued

Certification approved on 13 December, 2022

Delegated signatory

A handwritten signature in blue ink that reads 'George Nestic'.

George Nestic

Approvals Officer

13 December, 2022