



Ref. Certif. No.

FR_712540/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
1884 Boulevard de la Défense
92000 Nanterre France

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS
1884 Boulevard de la Défense
92000 Nanterre France

Name and address of the factory

Note: When more than one factory, please report on page 2

☒ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Com**PacT** NSX400 NA
Com**PacT** NSX630 NA

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_712540/M1 dated 18/07/2022.
Change name and address of licence holder
Change the list of factories

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020
IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

2011990016
2011990016A1
B260077

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 24/07/2026

Signature: **Julien GAUTHIER**
Certification Officer



ANNEX

Name and address of the factories:

SCHNEIDER (BEIJING) LOW VOLTAGE Co., Ltd

No 2, Liang Shui He 2nd Street, Beijing Economic Technological Development area
100176 BEIJING - China

SCHNEIDER ELECTRIC ALPES

Zone d'activités Alpespace, Rue Isaac Newton
73800 Porte-de-Savoie - France

SCHNEIDER ELECTRIC INDIA Pvt Ltd.

Survey No. 215, Gagillapur Village, Medak Road, Rangareddy District, HYDERABAD
500 043 TELANGANA, INDIA

SCHNEIDER ELECTRIC INDUSTRIE ITALIA S.P.A

Corso Italia 115, 80020 CASAVATORE (NA) - Italy

References, ratings and main characteristics:

Model	Rated current I_e (A)	Model	Rated current I_e (A)
NSX630 NA	630A	NSX400 NA	400A

Utilization category	AC-22A, AC-23A
Method of operation	Independent manual operation
Suitability for isolation	Suitable
Protection degree :	IP40 for front cover
Number of poles :	3P,4P
Kind of current :	AC
Rated operational voltage U_e : (V)	AC690V
Rated insulation voltage U_i : (V)	800V
Rated impulse withstand voltage U_{imp} : (V)	8kV
Conventional free air thermal current I_{th} : (A)	Same as I_e
Rated operational current I_e : (A)	See above table
Rated uninterrupted current I_u : (A)	Same as I_e
Rated short-time withstand current : I_{cw} (kA)	5kA/1s for NSX400NA; 7,6kA/1s for NSX630NA
Rated short-circuit making capacity : I_{cm} (kA)	7,1kA for NSX400NA; 8,5kA for NSX630NA



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 24/07/2026

Signature: **Julien GAUTHIER**

Certification Officer

