Ref. Certif. No.

FR_718990

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	**Transfer switching equipment** Transfer Switching Equipment (Class PC)
Name and address of the applicant	**Schneider Electric (China) Co., Ltd.** No.6, Wangjing East road, Chaoyang, Beijing - China
Name and address of the manufacturer	**Schneider Electric (China) Co., Ltd.** No.6, Wangjing East road, Chaoyang, Beijing - China
Name and address of the factory	**Schneider Wingoal (Tianjin)Electric Equipment Co.,Ltd.** No.11, Hi-Tech Chuang Xin No. 6 Rd, Hua Yuan Industrial Development Area (Outside Outer Ring), Binhai New Area Tianjin P.R. - China
Note: *When more than one factory, please report on page 2*	☐ Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark / Brand (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	TransferPacT TA1A400, TA1A500, TA1A630, TA1A800, TA1A1000, TA1A1250, TA1A1600
Additional information (if necessary may also be reported on page 2)	☐ Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2020 IEC 60947-6-1:2021
As shown in the Test Report Ref. No. which forms part of this Certificate	24119Y90006

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
92260 FONTENAY-AUX-ROSES

Date: 25/04/2024

Signature: Jérôme REYSSON
Certification Officer

ANNEX

References, ratings and main characteristics:

Class of equipment	PC
Method of controlling	ATSE
Number of poles	3P,4P
Rated operational voltage Ue (V)	380V/400V/415V/440V
Rated insulation voltage Ui (V)	1000V
Rated impulse withstand voltage Uimp (kV)	12kV
Conventional free air thermal current Ith (A)	1250A,1600A
Rated operational current Ie (A)	400A,500A,630A,800A,1000A,1250A,1600A
Rated frequency (Hz)	50/60Hz
Utilization category	AC-33A(Ie:400~1250A) AC-33B(Ie:1600A)
Rated short-time withstand current Icw (kA)	50kA/0,5s, 70kA/0,1s
Rated short-circuit making capacity Icm (kA)	105kA peak
Rated conditional short-circuit current Iq (kA)	Iq=150kA(SCPD type : circuit breaker) for Ie:400-1000A Iq=70kA(SCPD type: circuit breaker) for Ie:1250-1600A
EMC environment	Class A & B

Type explanation

TA 1A □ □ □ □ □ □ □ □

1 2 3 4 5 6 7 8 9 10

1-series number, TA: ATSE

2-frame, 1A:1600A

3-method of transfer, D: delay transfer (off delay)

4-poles, 3： 3P，4：4P

5-type of controller display,

L: Apro controller Acitve Automatic HMI

6- Rated operational current:

400：400A、500：500A、630：630A、800：800A: 10H：1000A、12H：1250A 、16H：1600A

6-Rated operational voltage:

4: 380V/400V/415V/440V 3P,4P

7-connection, T: top input and bottom output

8-Class PC

9-standard, E: IEC standard;

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 774
33 avenue du Général Leclerc
FR-92260 FONTENAY-AUX-ROSES

Date: 25/04/2024

Signature: Jérôme REYSSON
Certification Officer