Ref. Certif. No.

FR_721861

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	**Switching element** Tesys Auxiliary Contact Blocks
Name and address of the applicant	**SCHNEIDER ELECTRIC INDUSTRIES SAS** 35, rue Joseph Monier 92500 RUEIL-MALMAISON - FRANCE
Name and address of the manufacturer	**SCHNEIDER ELECTRIC INDUSTRIES SAS** 35, rue Joseph Monier 92500 RUEIL-MALMAISON - FRANCE
Name and address of the factory	**SCHNEIDER ELECTRIC A.S.** Cizovska 447 39701 PISEK - CZECH REPUBLIC
Note: *When more than one factory, please report on page 2*	☐ Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark / Brand (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	LA1SK11, LA1SK02, LA1SK20
Additional information (if necessary may also be reported on page 2)	Supersedes CBTC FR_709764 dated 25/11/2020. Update further to the evolution of the standard(s) ☐ Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2020 IEC 60947-5-1:2024
As shown in the Test Report Ref. No. which forms part of this Certificate	25119Y90029

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 362 174
33 avenue du Général Leclerc
92260 FONTENAY-AUX-ROSES

Date: 16/06/2025

Signature: Julien GAUTHIER
Certification Officer

ANNEX

References, ratings and main characteristics:

Type of contact elements	X, Y
Number of contacts	1NC+1NO, 2NC,2NO
Conventional free air thermal current Ith (A)	10A
Rated insulation voltage Ui (V)	690V
Rated impulse withstand voltage Uimp (kV)	6kV
Utilization category	AC-15, DC-13
Rated operational voltage Ue (V)	120VAC, 440VAC, 125VDC, 600VDC
Rated frequency (Hz)	50/60Hz for AC
Rated operational current Ie (A)	AC-15: Ue/Ie: 120V/6A, 440V1,64A DC-13: Ue/Ie: 125V/0,55A, 600V/0,1A
Rated conditional short-circuit current (kA)	1kA
kind of protective device	Fuse gG 10A

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 16/06/2025

Signature: Julien GAUTHIER
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES