

GEX26749

PLEASE NOTE

- The installation, maintenance and eventual replacement of this device must only be carried out by a qualified electrician.
- This device must not be repaired.
- All applicable local, regional and national regulations must be complied with during the installation, use, maintenance and replacement of this device.
- This device should not be installed if, when unpacking it, you observe that it is damaged.
- Schneider Electric cannot be held responsible in the event of noncompliance with the instructions in this document and in the documents to which it refers.
- The service instruction must be observed throughout the life time of this device.

Surge protection device (SPD)
Compliant with IEC 61643-11

Schneider Electric


⚠⚠ DANGER


HAZARD OF ELECTRIC SHOCK, EXPLOSION OR ARC FLASH

- Turn off all power supplying this product before working on it.
- Use a voltage tester with a suitable rated voltage in order to check that all active conductors aren't energized.
- Carefully inspect the work area to check that no tools or objects could have been left inside the equipment.

Failure to follow these instructions will result in death or serious injury.


1 Description






- A B Terminal block for remote alarm
- C Connection terminal
- D End of life indicator:
  - White: ok
  - Red: end of life
- E Clip for DIN rail mounting


2 Installation



Isc	Backup CB
≤ 10 kA	Resi9 MCB 40 A

Typical SPD installation in switchboard with MEN






14 mm	2.5...25 mm²	4...16 mm²
3.5 N.m	6.5 mm	PZ2


3 Installation verification test

NOTICE
HAZARD OF PRODUCT DAMAGE DURING INSULATION RESISTANCE TEST The device must be disconnected before performing the insulation resistance test. **Failure to follow these instructions can result in equipment damage.**

4 Cartridge replacement



5 More information



Schneider Electric Industries SAS
35, rue Joseph Monier
CS 30323
F - 92506 Rueil Malmaison Cedex
www.se.com

© 2023 Schneider Electric - All rights reserved.