Ref. Certif. No.

HU-003258-A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch-disconnector
Name and address of the applicant	Schneider Electric Industries SAS 35 rue Joseph Monier 92500 Rueil-Malmaison, France
Name and address of the manufacturer	Schneider Electric Industries SAS 35 rue Joseph Monier 92500 Rueil-Malmaison, France
Name and address of the factory	Schneider (Beijing) Low Voltage Co., Ltd No.2, Liang Shui He 2nd street, Beijing Economic and Technological Development Area, Beijing, P.R. China
Ratings and principal characteristics	Ui=1600V; Uimp=8kV; 4P appearance; No polarity; DC-22A,DC-PV2:Ue=1500VDC; Ie=320/400/500/630A; Icw=7,56kA,1s; Icm=7,56kA; Ith:same as Ie
Trademark (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	NSX630 NA DC EP
Additional information (if necessary may also be reported on page 2)	This Certificate is Modification No.1 to CBTC ref. No. HU-003258, dated 2021-01-11, and is issued due to change of factory's name.
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	50432585 002

This CB Test Certificate is issued by the National Certification Body

TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2022-06-08

Signature: Wencai Zhang

10/0861 CB 06/20v9 rk

Disclaimer: This is an electronically released document. The authenticity of this certificate can be verified on the IECEE Website "http://certificates.iecee.org"