Ref. Certif. No.
NL-60948

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

# CB TEST CERTIFICATE

| | |
|---|---|
| Product | Surge Protective Devices |
| Name and address of the applicant | Schneider Electric Industries SAS<br>31 rue Pierre Mendes, Eybens F-38050 Grenoble Cedex 9,<br>France |
| Name and address of the manufacturer | Schneider Electric Industries SAS<br>31 rue Pierre Mendes, Eybens F-38050 Grenoble Cedex 9,<br>France |
| Name and address of the factory<br>Note: *When more than one factory, please report on page 2* | ☐ Additional information on page 2<br>Schneider Shanghai Low Voltage Terminal Apparatus Co., Ltd.<br>No. 119 Ping'an Road, Minhang District, Shanghai,<br>China |
| Ratings and principal characteristics | Test class I/Type 1 and Test class II/Type 2, Isccr: 50 kA, IP20;<br>L-N: Uc: 350 V~, Iimp: 12,5 kA, In: 20 kA, Imax: 50 kA, Up: 1,5 kV;<br>N-PE: Uc: 260 V~, Iimp: 50 kA, In: 20 kA, Imax: 50 kA, Up: 1,5 kV |
| Trademark (if any) | Schneider Electric |
| Customer's Testing Facility (CTF) Stage used | |
| Model / Type Ref. | A9L16182 (iPRD1 12.5r 1P), A9L16282 (iPRD1 12.5r 1P+N),<br>A9L16382 (iPRD1 12.5r 3P), A9L16482 (iPRD1 12.5r 3P+N),<br>A9L16082 (Cartridge C12.5 350) |
| Additional information (if necessary may also be reported on page 2) | ☐ Additional information on page 2 |
| A sample of the product was tested and found to be in conformity with | IEC 61643-11:2011<br>National differences:<br>EU Group Differences |
| As shown in the Test Report Ref. No. which forms part of this Certificate | 6049070.50 |

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

DEKRA

Date: 2020-01-13

Signature: Kate Xu