Ref. Certif. No.

NL-81246

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Anti-Tripping Module 3P
Name and address of the applicant	Schneider Electric Industries SAS 35, rue Joseph Monier, 92500 Rueil Malmaison France
Name and address of the manufacturer	Schneider Electric Industries SAS 31, rue Pierre Mendès France, 38320 Eybens France
Name and address of the factory *Note: When more than one factory, please report on page 2*	Wanbang Digital Energy Co., Ltd. No. 39 Longhui Road, Wujin High-tech Zone, Changzhou, Jiangsu China ☐ Additional information on page 2
Ratings and principal characteristics	AC 220/230/240 V(L-N), 50/60 Hz, ≤5 W, 3P4W
Trademark (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	EVA1HPC3
Additional information (if necessary may also be reported on page 2)	☐ Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61010-1:2010, IEC 61010-1:2010/AMD1:2016 National differences: EU Group Differences
As shown in the Test Report Ref. No. which forms part of this Certificate	6130340.50(A-B)

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands

DEKRA

Date: 2022-06-02

Signature: Kreny Lin