CENELEC CERTIFICATION AGREEMENT

ACCORD DE CERTIFICATION DU CENELEC
CENELEC-ZERTIFIZIERUNGS-ABKOMMEN

IMQ S.p.A. • www.imq.it
I • 20138 MI • via Quintiliano 43

CCA

STATEMENT OF TEST RESULTS

STR/2761/IMQ

Product	**Circuit-breakers for overcurrent protection for household and similar installations**
Tested by request of	**SCHNEIDER ELECTRIC INDUSTRIES SAS** **31 rue Pierre Mendès France, Eybens** **F-38050 Grenoble Cedex 9 – France**
Manufactured at (name and place)	**Schneider Electric Bulgaria EOOD** **Plovdiv plant** **4202 Radinovo – Bulgaria** *or* **Schneider Electric Thailand Co., Ltd.** **540 Soi 9 Bangpoo Industrial estate, Sukhmvit Road, Muang District** **10280 Samutprakarn – Thailand**
Preliminary visit carried out by	—
Rating and principal characteristics	**1P (Ue 230 V), 1P+N (Ue 230 V), 2P (Ue 400 V), 3P (Ue 400 V) or 4P (Ue 400 V); 50-60 Hz; curve C; In: 6, 10, 16, 20, 25 or 32 A; Icn: 6000 A** *(see also pages 8 and 9 of Test Report No. PB26-0137071-02-00)*
Trade mark (if any)	Schneider Electric
Model/Type Ref.	**Resi9 XP 6000 series** *(see also Additional Sheet)*
Additional information (if necessary)	—

A sample of the product has been tested and found to be in conformity with (HD/EN and equivalent national standard)

• EN 60898-1:2019 + A1:2024 + A11:2024

as shown in the test reports (reference No.)

- **CVPB26-0137071-02**
- **PB26-0137071-02-00 and from PB26-0137071-02-01 to PB26-0137071-02-18**

This Statement of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the above mentioned standard.

This Statement of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983 and September 3rd, 2004 (including addendum 1 dated July 1984, addendum 2 dated March 1987, addendum 3 dated September 1989 and addendum 4 dated March 1995). Any other body participating in the CCA may recognize this Statement as a basis for granting a national mark of conformity or a national approval, as specified in OD 6, List of current decisions of CCA Group, point 2.11.

IMQ S.p.A.

Signature of the authorized person Giorgio Belussi

Name and function of the authorized person

Giorgio Belussi
Business Unit "Product"
Head of Certification area

Milano, ***2026-10-20***

Via Quintiliano, 43 – 20138 Milano – Italy
Phone: (+39) 0250731
Fax: (+39) 0250991500
e-mail: info@imq.it

Generic reference of the circuit-breakers for overcurrent protection Resi9 XP 6000 series and related ratings

Number of poles	Rated voltage (U_e)	Rated current (I_n)	Generic reference
1P	230 V	6 A	R9P6DOM1C6
		10 A	R9P6DOM1C10
		16 A	R9P6DOM1C16
		20 A	R9P6DOM1C20
		25 A	R9P6DOM1C25
		32 A	R9P6DOM1C32
1P+N	230 V	6 A	R9P6DOMPhNC6
		10 A	R9P6DOMPhNC10
		16 A	R9P6DOMPhNC16
		20 A	R9P6DOMPhNC20
		25 A	R9P6DOMPhNC25
		32 A	R9P6DOMPhNC32
2P	400 V	6 A	R9P6DOM2C6
		10 A	R9P6DOM2C10
		16 A	R9P6DOM2C16
		20 A	R9P6DOM2C20
		25 A	R9P6DOM2C25
		32 A	R9P6DOM2C32
3P	400 V	6 A	R9P6DOM3C6
		10 A	R9P6DOM3C10
		16 A	R9P6DOM3C16
		20 A	R9P6DOM3C20
		25 A	R9P6DOM3C25
		32 A	R9P6DOM3C32
4P	400 V	6 A	R9P6DOM4C6
		10 A	R9P6DOM4C10
		16 A	R9P6DOM4C16
		20 A	R9P6DOM4C20
		25 A	R9P6DOM4C25
		32 A	R9P6DOM4C32