

## **C-Bus Application Messages & Behaviour**

### **Chapter 10 – Ventilation (Fans & Dampers)**

Document Number: CBUS-APP/10

Issue: 1.2

Date: 13 February 2007

**Comments on this document should be addressed to:**

**Engineering Manager  
Clipsal Integrated Systems  
PO Box 103 Hindmarsh  
South Australia 5007**

---

**C-Bus Ventilation (Fans and Dampers) Application**

---

**TABLE OF CONTENTS**

10	Ventilation (Fans and Dampers) Application.....	3
10.1	Application ID.....	3
10.2	Description.....	3

---

## **C-Bus Ventilation (Fans and Dampers) Application**

---

### **10 VENTILATION (FANS AND DAMPERS) APPLICATION**

#### **10.1 *Application ID***

\$70

#### **10.2 *Description***

This application is defined to confine the messages and use of C-Bus devices, used for ventilation control (such as but not limited to Fans and Airconditioning Dampers).

The messages used for this application are identical to standard C-Bus lighting control messages. Reference should be made to Chapter 2 of this document set (CBUS-APP/02 C-Bus Lighting Application) for further information.