

C-Bus Application Messages & Behaviour

Chapter 36 – HVAC Actuator

Document Number: CBUS-APP/36

Issue: 1.0

Date: 1 March 2007

Comments on this document should be addressed to:

**Engineering Manager
Clipsal Integrated Systems
PO Box 103 Hindmarsh
South Australia 5007**

C-Bus HVAC Actuator Application

TABLE OF CONTENTS

36	HVAC Actuator Application	3
	36.1 Application ID.....	3
	36.2 Description.....	3

C-Bus HVAC Actuator Application

36 HVAC ACTUATOR APPLICATION

36.1 Application ID

\$73 and \$74

36.2 Description

These applications are defined to confine the messages and use of C-Bus devices used for linking a C-Bus thermostat to a an actuator, such as a relay, which in turn switches furnaces, compressors, valves, and so on.

The messages used for this application are identical to standard C-Bus lighting control messages. Reference should be made to Chapter 2 of this document set (CBUS-APP/02 C-Bus Lighting Application) for further information.

Whilst any C-Bus lighting-like application could be used for messages that link a thermostat to an actuator, the use of these applications makes it easy for an installer to lump related functions together for clarity and simplicity.