Statement Of Test Results

The observations and test/inspection results referenced in this Statement are relevant only to the sample tested/inspected at the time the tests were carried out, see additional information.

Applicant Name & Address:	Schneider Electric Industries SAS 35 rue Joseph Monier FR – Rueil Malmaison 92500
Product Description:	Medium Voltage Variable Speed Drive
Ratings & Principle Characteristics:	Control Power: 100~240Vac, 50Hz, 1PH, 1kVA Fan Power Supply: 400Vac, 50Hz, 3PH, 60kVA Rated Input Power: 20000kVA Rated Input Voltage: 22kV, 50Hz, 3PH Rated Output Votage & Current: 0-13.8kV, 0-60Hz, 3PH, 1000A
Models/Type References:	ATV6000 Series
Brand Name(s):	Schneider Electric
Standard(s):	IEC 61800-5-1:2007 IEC 61800-3:2017
Verification Issuing Office Name & Address:	Intertek Semko AB Torshamnsgatan 43, SE-164 22 Kista, SWEDEN
Test Report Number(s):	260313101GZU-001, 2603B1107SHA-001
Additional information:	The stated results are based on tests and evaluation performed and reported on existing test reports conducted by other parties. The tests compilation is based on previous test data from various test data sheets used to demonstrate compliance with the relevant standards. The test methods and test datasheets related to the assessment are clearly documented and referenced within the corresponding sections of each report.



Signature

Name: Mats Nordin
Position: Business Area Manager
Date: 27 July 2026

This Statement is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Statement. Only the Client is authorized to permit copying or distribution of this Statement. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Statement are relevant only to the sample tested/inspected. This Statement by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.